

CSUDH Potable Water Lead Testing
Sampling and lab result summary

Building Name	Location	Source Type	Sample ID(s)	Date Sampled	Result	Comments
Baseball Field	Left dugout	Drinking Fountain	1910033-BF1-129	5/9/2019	None detected	
Baseball Field	Right dugout	Drinking Fountain	1910033-BF2-130	5/9/2019	None detected	
Baseball Storage	Near the Women's Rest Room D001	Drinking Fountain	1910033-BS1-126	5/9/2019	None detected	
Child Development Center	CDC Inside Room 106	Kitchen with sink	1910033-CDC-1	5/14/2018	None detected	
Child Development Center	CDC Outside Room 111	Drinking Fountain	1910033-CDC-2	5/14/2018	None detected	
Central Plant	Next to Locker Room CP-A-021-E, Break Room	Sink	1910033-CP1-46	12/4/2018	1.13	
Central Plant	Next to Men's Rest Room CPA-021-D	Drinking Fountain	1910033-CP2-47	12/4/2018	None detected	
College of Education	Room 1428, Break Room	Sink	1910033-COE1-50	12/7/2018	1.27	
College of Education	Across from Room 1428	Drinking Fountain	1910033-COE2-51	12/7/2018	2.24	
College of Education	Across from Room 1428	Drinking Fountain	1910033-COE3-52	12/7/2018	None detected	
East Academic Complex	Near the Women's Rest Room 1001	Drinking Fountain	1910033-EAC-131	5/9/2019	None detected	
Extended Education	Next to Women's Rest Room EXE 1212	Drinking Fountain (left)	1910033-EE1-132	5/9/2019	None detected	
Extended Education	Next to Women's Rest Room EXE 1212	Drinking Fountain (right)	1910033-EE2-133	5/9/2019	None detected	
Extended Education	Next to Men's Rest Room EXE 1327	Drinking Fountain (left)	1910033-EE3-134	5/9/2019	None detected	
Extended Education	Next to Men's Rest Room EXE 1327	Drinking Fountain (right)	1910033-EE4-135	5/9/2019	1.37	
Extended Education	EXE 1325	Break room with sink	1910033-EE5-136	5/9/2019	None detected	
Extended Education	EXE 1301A	Kitchen with sink	1910033-EE6-137	5/9/2019	None detected	
Facilities	F-011 of main building, Break Room	Sink	1910033-PP3-20	12/3/2018	1.41	
Facilities	Outside of Carpenter Shop, Break Room	Sink	1910033-PP1-18	12/3/2018	None detected	
Facilities	Maintenance Shop	Kitchen with sink	1910033-PP4-21	12/3/2018	None detected	
Athletics Field House	Next to FH C-008	Drinking Fountain	1910033-FH2-2	12/3/2018	2.30	
Athletics Field House	Next to FH B-009	Bottle Filler	1910033-FH1-1	12/3/2018	None detected	
Gymnasium	Men's Locker Room B-104	Drinking Fountain	1910033-GYM3-6	12/3/2018	1.44	
Gymnasium	Basketball floor far end	Drinking Fountain	1910033-GYM2-5	12/3/2018	1.58	
Gymnasium	Women's Locker Room B-102	Drinking Fountain	1910033-GYM4-7	12/3/2018	5.60	
Gymnasium	Outdoor Pool	Drinking Fountain	1910033-GYM5-8	12/4/2018	12.10	
Gymnasium	Basketball floor far end	Drinking Fountain	1910033-GYM1-4	12/3/2018	None detected	
Housing	C6	Kitchen with sink	1910033-C6-70	5/23/2018	1.06	
Housing	A	Kitchen with sink	1910033-A-61	5/23/2018	1.08	
Housing	W4	Kitchen with sink	1910033-W4-245	6/22/2018	1.29	
Housing	N5	Kitchen with sink	1910033-N5-108	5/23/2018	1.33	
Housing	L6	Kitchen with sink	1910033-L6-96	5/23/2018	1.38	
Housing	H6	Kitchen with sink	1910033-H6-184	6/12/2018	1.39	
Housing	I1	Kitchen with sink	1910033-I1-188	6/11/2018	1.39	
Housing	I7	Kitchen with sink	1910033-I7-82	5/23/2018	1.39	
Housing	O2	Kitchen with sink	1910033-O2-113	5/23/2018	1.42	
Housing	U6	Kitchen with sink	1910033-U6-238	6/12/2018	1.46	
Housing	D2	Kitchen with sink	1910033-D2-73	5/23/2018	1.52	
Housing	J8	Kitchen with sink	1910033-J8-83	5/23/2018	1.52	
Housing	B4	Kitchen with sink	1910033-B4-65	5/23/2018	1.57	
Housing	N4	Kitchen with sink	1910033-N4-107	5/23/2018	1.61	
Housing	N6	Kitchen with sink	1910033-N6-109	5/23/2018	1.61	
Housing	C1	Kitchen with sink	1910033-C1-66	5/23/2018	1.68	
Housing	M8	Kitchen with sink	1910033-M8-104	5/23/2018	1.72	
Housing	U4	Kitchen with sink	1910033-U4-237	6/12/2018	1.73	
Housing	J6	Kitchen with sink	1910033-J6-81	5/23/2018	1.74	
Housing	L7	Kitchen with sink	1910033-L7-97	5/23/2018	1.77	
Housing	H8	Kitchen with sink	1910033-H8-186	6/11/2018	1.81	
Housing	H1	Kitchen with sink	1910033-H1-179	6/11/2018	1.83	
Housing	C7	Kitchen with sink	1910033-C7-71	5/23/2018	1.87	
Housing	G5	Kitchen with sink	1910033-G5-175	6/11/2018	1.88	
Housing	N8	Kitchen with sink	1910033-N8-111	5/23/2018	1.89	
Housing	M7	Kitchen with sink	1910033-M7-103	5/23/2018	2.01	
Housing	H7	Kitchen with sink	1910033-H7-185	6/29/2018	2.04	
Housing	N1	Kitchen with sink	1910033-N1-105	5/23/2018	2.07	
Housing	M3	Kitchen with sink	1910033-M3-205	6/11/2018	2.12	
Housing	J1	Kitchen with sink	1910033-J1-78	5/23/2018	2.13	
Housing	C3	Kitchen with sink	1910033-C3-151	6/11/2018	2.18	
Housing	I2	Kitchen with sink	1910033-I2-189	6/12/2018	2.21	
Housing	B1	Kitchen with sink	1910033-B1-62	5/23/2018	2.22	
Housing	C5	Kitchen with sink	1910033-C5-69	5/23/2018	2.22	
Housing	L1	Kitchen with sink	1910033-L1-91	5/23/2018	2.25	
Housing	O3	Kitchen with sink	1910033-O3-114	5/23/2018	2.26	
Housing	G4	Kitchen with sink	1910033-G4-174	6/11/2018	2.28	
Housing	N7	Kitchen with sink	1910033-N7-110	5/23/2018	2.32	
Housing	G3	Kitchen with sink	1910033-G3-173	6/11/2018	2.34	
Housing	H5	Kitchen with sink	1910033-H5-183	6/22/2018	2.41	
Housing	E5	Kitchen with sink	1910033-E5-159	6/11/2018	2.47	
Housing	J2	Kitchen with sink	1910033-J2-79	5/23/2018	2.47	
Housing	N2	Kitchen with sink	1910033-N2-106	5/23/2018	2.47	
Housing	E4	Kitchen with sink	1910033-E4-158	6/11/2018	2.24, 2.48	
Housing	E8	Kitchen with sink	1910033-E8-162	6/11/2018	2.49	
Housing	M1	Kitchen with sink	1910033-M1-98	5/23/2018	2.49	
Housing	O4	Kitchen with sink	1910033-O4-115	5/23/2018	2.50	
Housing	B2	Kitchen with sink	1910033-B2-63	5/23/2018	2.51	
Housing	L4	Kitchen with sink	1910033-L4-94	5/23/2018	2.52	
Housing	C2	Kitchen with sink	1910033-C2-67	5/23/2018	2.54	
Housing	G6	Kitchen with sink	1910033-G6-176	6/11/2018	2.65	
Housing	L8	Kitchen with sink	1910033-L8-204	6/11/2018	2.68	
Housing	S2	Kitchen with sink	1910033-S2-248	6/22/2018	2.73	
Housing	N3	Kitchen with sink	1910033-N3-208	6/22/2018	2.80	
Housing	H2	Kitchen with sink	1910033-H2-180	6/11/2018	2.81	
Housing	O1	Kitchen with sink	1910033-O1-112	5/23/2018	2.86	
Housing	C4	Kitchen with sink	1910033-C4-68	5/23/2018	2.90	
Housing	J5	Kitchen with sink	1910033-J5-80	5/23/2018	2.90	
Housing	I4	Kitchen with sink	1910033-I4-199	6/11/2018	2.91	
Housing	M2	Kitchen with sink	1910033-M2-99	5/23/2018	2.94	
Housing	G1	Kitchen with sink	1910033-G1-171	6/11/2018	2.98	
Housing	E1	Kitchen with sink	1910033-E1-155	6/11/2018	3.02	
Housing	G7	Kitchen with sink	1910033-G7-177	6/11/2018	3.10	
Housing	M6	Kitchen with sink	1910033-M6-102	5/23/2018	3.24	
Housing	D1	Kitchen with sink	1910033-D1-152	6/11/2018	3.36	
Housing	H3	Kitchen with sink	1910033-H3-181	6/11/2018	3.44	
Housing	K8	Kitchen with sink	1910033-K8-90	6/12/2018	3.44	
Housing	J3	Kitchen with sink	1910033-J3-198	6/11/2018	3.49	
Housing	I5	Kitchen with sink	1910033-I5-192	6/11/2018	3.54	
Housing	I6	Kitchen with sink	1910033-I6-146	5/23/2018	3.54	
Housing	E3	Kitchen with sink	1910033-E3-157	6/11/2018	3.61	
Housing	E2	Kitchen with sink	1910033-E2-156	6/11/2018	3.69	
Housing	H4	Kitchen with sink	1910033-H4-182	6/11/2018	3.69	
Housing	B3	Kitchen with sink	1910033-B3-64	6/11/2018	3.82	
Housing	E6	Kitchen with sink	1910033-E6-160	6/11/2018	3.88	
Housing	L2	Kitchen with sink	1910033-L2-92	5/23/2018	3.89	
Housing	D3	Kitchen with sink	1910033-D3-74	5/23/2018	3.94	
Housing	K6	Kitchen with sink	1910033-K6-88	6/11/2018	4.02	
Housing	I3	Kitchen with sink	1910033-I3-190	6/22/2018	4.13	
Housing	K3	Kitchen with sink	1910033-K3-252	7/9/2018	4.16	
Housing	I4	Kitchen with sink	1910033-I4-143	5/23/2018	4.24	

CSUDH Potable Water Lead Testing
Sampling and lab result summary

Building Name	Location	Source Type	Sample ID(s)	Date Sampled	Result	Comments
Housing	F1	Kitchen with sink	1910033-F1-163	6/22/2018	4.25	
Housing	D4	Kitchen with sink	1910033-D4-153	6/11/2018	4.27	
Housing	I8	Kitchen with sink	1910033-I8-145	5/23/2018	4.27	
Housing	K5	Kitchen with sink	1910033-K5-87	6/11/2018	4.31	
Housing	E7	Kitchen with sink	1910033-E7-161	6/11/2018	4.35	
Housing	D6	Kitchen with sink	1910033-D6-76	6/11/2018	4.50	
Housing	G2	Kitchen with sink	1910033-G2-172	6/11/2018	4.80	
Housing	M4	Kitchen with sink	1910033-M4-100	5/23/2018	4.98	
Housing	F5	Kitchen with sink	1910033-F5-167	6/11/2018	5.01	
Housing	K7	Kitchen with sink	1910033-K7-89	6/11/2018	5.03	
Housing	K1	Kitchen with sink	1910033-K1-84	6/11/2018	5.23	
Housing	F6	Kitchen with sink	1910033-F6-168	6/11/2018	5.29	
Housing	D5	Kitchen with sink	1910033-D5-75	5/23/2018	5.36	
Housing	F8	Kitchen with sink	1910033-F8-170	6/11/2018	5.54	
Housing	L5	Kitchen with sink	1910033-L5-95	5/23/2018	5.65	
Housing	K4	Kitchen with sink	1910033-K4-86	6/11/2018	5.94	
Housing	G8	Kitchen with sink	1910033-G8-178	6/11/2018	6.38	
Housing	C8	Kitchen with sink	1910033-C8-72	6/11/2018	6.44	
Housing	D7	Kitchen with sink	1910033-D7-154	6/11/2018	6.51	
Housing	F2	Kitchen with sink	1910033-F2-164	6/11/2018	6.84	
Housing	I7	Kitchen with sink	1910033-I7-144	5/23/2018	7.34	
Housing	F3	Kitchen with sink	1910033-F3-165	6/11/2018	7.46	
Housing	K2	Kitchen with sink	1910033-K2-85	6/11/2018	8.17	
Housing	L3	Kitchen with sink	1910033-L3-93	5/23/2018	8.31	
Housing	X	Drinking Fountain	1910033-X-138	5/23/2018	8.48	
Housing	D8	Kitchen with sink	1910033-D8-77	6/11/2018	9.07	
Housing	F4	Kitchen with sink	1910033-F4-166	6/11/2018	9.74	
Housing	F7	Kitchen with sink	1910033-F7-169	6/11/2018	11.20	
Housing	M5	Kitchen with sink	1910033-M5-101, 1910033-M5-206, 1910033-M5-207, 1910033-M5-250, 1910033-M5-251	5/23/2018, 6/12/18, 6/29/18	36.9, 4.69, 1.09, 2.72, None detected	
Housing	P1	Kitchen with sink	1910033-P1-116	5/23/2018	None detected	
Housing	P2	Kitchen with sink	1910033-P2-117	6/11/2018	None detected	
Housing	P3	Kitchen with sink	1910033-P3-209	6/11/2018	None detected	
Housing	P4	Kitchen with sink	1910033-P4-118	5/23/2018	None detected	
Housing	P5	Kitchen with sink	1910033-P5-210	6/11/2018	None detected	
Housing	P6	Kitchen with sink	1910033-P6-211	6/11/2018	None detected	
Housing	P7	Kitchen with sink	1910033-P7-212	6/11/2018	None detected	
Housing	P8	Kitchen with sink	1910033-P8-213	6/12/2018	None detected	
Housing	Q1	Kitchen with sink	1910033-Q1-148	5/23/2018	None detected	
Housing	Q2	Kitchen with sink	1910033-Q2-147	5/23/2018	None detected	
Housing	Q3	Kitchen with sink	1910033-Q3-216	6/11/2018	None detected	
Housing	Q4	Kitchen with sink	1910033-Q4-217	6/22/2018	None detected	
Housing	Q5	Kitchen with sink	1910033-Q5-149	5/23/2018	None detected	
Housing	Q6	Kitchen with sink	1910033-Q6-150	5/23/2018	None detected	
Housing	Q7	Kitchen with sink	1910033-Q7-220	6/12/2018	None detected	
Housing	Q8	Kitchen with sink	1910033-Q8-221	6/11/2018	None detected	
Housing	R1	Kitchen with sink	1910033-R1-222	6/22/2018	None detected	
Housing	R2	Kitchen with sink	1910033-R2-223	6/29/2018	None detected	
Housing	R3	Kitchen with sink	1910033-R3-224	6/11/2018	None detected	
Housing	R4	Kitchen with sink	1910033-R4-225	6/22/2018	None detected	
Housing	R5	Kitchen with sink	1910033-R5-226	6/22/2018	None detected	
Housing	R6	Kitchen with sink	1910033-R6-227	6/22/2018	None detected	
Housing	R7	Kitchen with sink	1910033-R7-228	6/22/2018	None detected	
Housing	R8	Kitchen with sink	1910033-R8-229	6/22/2018	None detected	
Housing	S1	Kitchen with sink	1910033-S1-119	5/23/2018	None detected	
Housing	S3	Kitchen with sink	1910033-S3-230	6/12/2018	None detected	
Housing	S4	Kitchen with sink	1910033-S4-120	5/23/2018	None detected	
Housing	T1	Kitchen with sink	1910033-T1-231	6/12/2018	None detected	
Housing	T2	Kitchen with sink	1910033-T2-121	5/23/2018	None detected	
Housing	T3	Kitchen with sink	1910033-T3-232	6/22/2018	None detected	
Housing	T4	Kitchen with sink	1910033-T4-122	6/12/2018	None detected	
Housing	T5	Kitchen with sink	1910033-T5-233	6/12/2018	None detected	
Housing	T6	Kitchen with sink	1910033-T6-234	6/12/2018	None detected	
Housing	T7	Kitchen with sink	1910033-T7-123	5/23/2018	None detected	
Housing	T8	Kitchen with sink	1910033-T8-235	6/12/2018	None detected	
Housing	U1	Kitchen with sink	1910033-U1-124	6/12/2018	None detected	
Housing	U2	Kitchen with sink	1910033-U2-249	6/22/2018	None detected	
Housing	U3	Kitchen with sink	1910033-U3-236	6/12/2018	None detected	
Housing	U5	Kitchen with sink	1910033-U5-125	5/23/2018	None detected	
Housing	U7	Kitchen with sink	1910033-U7-239	6/12/2018	None detected	
Housing	U8	Kitchen with sink	1910033-U8-126	5/23/2018	None detected	
Housing	V1	Kitchen with sink	1910033-V1-127	5/23/2018	None detected	
Housing	V2	Kitchen with sink	1910033-V2-128	5/23/2018	None detected	
Housing	V3	Kitchen with sink	1910033-V3-240	6/22/2018	None detected	
Housing	V4	Kitchen with sink	1910033-V4-129	5/23/2018	None detected	
Housing	V5	Kitchen with sink	1910033-V5-241	6/12/2018	None detected	
Housing	V6	Kitchen with sink	1910033-V6-242	6/12/2018	None detected	
Housing	V7	Kitchen with sink	1910033-V7-130	5/23/2018	None detected	
Housing	V8	Kitchen with sink	1910033-V8-131	5/23/2018	None detected	
Housing	W1	Kitchen with sink	1910033-W1-132	5/23/2018	None detected	
Housing	W2	Kitchen with sink	1910033-W2-243	6/22/2018	None detected	
Housing	W3	Kitchen with sink	1910033-W3-244	6/22/2018	None detected	
Housing	W5	Kitchen with sink	1910033-W5-133	5/23/2018	None detected	
Housing	W6	Kitchen with sink	1910033-W6-134	5/23/2018	None detected	
Housing	W7	Kitchen with sink	1910033-W7-135	5/23/2018	None detected	
Housing	W8	Kitchen with sink	1910033-W8-136	5/23/2018	None detected	
Housing	X	Bottle Filler	1910033-X-137	5/23/2018	None detected	
Infant Toddler Development Cntr	ITC - 130	Drinking Fountain	1910033-ITC-1	5/7/2018	None detected	
Infant Toddler Development Cntr	ITC - 132	Kitchen with sink	1910033-ITC-2	5/14/2018	None detected	
La Corte Hall	Next to LCH A-325	Drinking Fountain	1910033-LCH1-9	12/3/2018	1.31	
La Corte Hall	Next to Men's Rest Room LCH B-319	Drinking Fountain	1910033-LCH3-11	12/3/2018	1.88	
La Corte Hall	Near LCH A-111	Drinking Fountain	1910033-LCH10-73	12/3/2018	2.31	
La Corte Hall	LCH E-306	Kitchen with sink	1910033-LCH5-13	12/3/2018	2.33	
La Corte Hall	Next to LCH C-314	Drinking Fountain	1910033-LCH2-10	12/3/2018	5.26	
La Corte Hall	Next to LCH A-348	Drinking Fountain	1910033-LCH4-12	12/3/2018	5.86	
La Corte Hall	Next to LCH A-202	Drinking Fountain	1910033-LCH7-15	12/3/2018	6.14	
La Corte Hall	Next to Women's Rest Room LCH A-214	Drinking Fountain	1910033-LCH6-14	12/3/2018	None detected	
La Corte Hall	Across from LCH A-103	Bottle Filler	1910033-LCH8-16	12/3/2018	None detected	
La Corte Hall	Across from LCH A-104	Drinking Fountain	1910033-LCH9-17	12/3/2018	None detected	
Library North	By Elevator on 1st Floor	Drinking Fountain	1910033-LIB4-26	12/4/2018	1.12	
Library North	By Elevator on 1st Floor	Drinking Fountain	1910033-LIB3-25	12/4/2018	1.19	
Library North	Near elevator on 5th Floor	Drinking Fountain	1910033-LIB6-38	12/4/2018	1.86	
Library North	Near elevator on 5th Floor	Drinking Fountain	1910033-LIB7-39	12/4/2018	2.22	

CSUDH Potable Water Lead Testing
Sampling and lab result summary

Building Name	Location	Source Type	Sample ID(s)	Date Sampled	Result	Comments
Library North	LIB A-121 Lounge Lizards	Kitchen with sink	1910033-LIB1-23	12/4/2018	2.54	
Library North	LIB 5510	Kitchen with sink	1910033-LIB19-41	12/4/2018	5.78	
Library North	LIB 5470, Break Room	Sink	1910033-LIB18-40	12/4/2018	6.17	
Library North	Across from LIB G-149	Drinking Fountain	1910033-LIB6-28, 1910033-LIB6-75	12/4/2018, 01/03/2019	20.9, 22.8	Facility to be replaced
Library North	LIB E-156 Custodial Break Room	Sink	1910033-LIB2-24	12/4/2018	None detected	
Library North	Near elevator in lobby on 2nd Floor	Drinking Fountain	1910033-LIB7-29	12/4/2018	None detected	
Library North	Near elevator in lobby on 2nd Floor	Drinking Fountain	1910033-LIB8-30	12/4/2018	None detected	
Library North	Near elevator by LIB 3524	Drinking Fountain	1910033-LIB9-31	3/14/2019	None detected	
Library North	Near elevator by LIB 3524	Drinking Fountain	1910033-LIB10-32	3/14/2019	None detected	
Library North	Near elevator on 4th Floor	Drinking Fountain	1910033-LIB13-35	3/14/2019	None detected	
Library North	Near elevator on 4th Floor	Drinking Fountain	1910033-LIB14-36	3/14/2019	1.16	
Library South	1st Floor, Room 1940D	Kitchen with sink	1910033-LIB51-98	4/9/2019	None detected	
Library South	Next to 1st floor Men's Rest Room LIB SOU 1936	Drinking Fountain (left)	1910033-LIB52-99	4/9/2019	None detected	
Library South	Next to 1st floor Men's Rest Room LIB SOU 1936	Drinking Fountain (right)	1910033-LIB53-100	4/9/2019	11.3	
Library South	Next to 1st floor Women's Rest Room LIB SOU 1901	Drinking Fountain			Not Sampled	Broken
Library South	Next to 1st floor Women's Rest Room LIB SOU 1901	Drinking Fountain			Not Sampled	Broken
Library South	1st Floor, Room 1010	Break room with sink	1910033-LIB54-101	4/9/2019	None detected	
Library South	Next to 2nd floor Women's Rest Room LIB SOU 2001	Drinking Fountain (left)	1910033-LIB55-102	4/9/2019	None detected	
Library South	Next to 2nd floor Women's Rest Room LIB SOU 2001	Drinking Fountain (right)	1910033-LIB56-103	4/9/2019	None detected	
Library South	2nd Floor, 2037A	Break room with sink	1910033-LIB57-104	4/9/2019	None detected	
Library South	Next to 2nd floor Men's Rest Room LIB SOU 2057	Drinking Fountain (left)	1910033-LIB58-105	4/9/2019	None detected	
Library South	Next to 2nd floor Men's Rest Room LIB SOU 2057	Drinking Fountain (right)	1910033-LIB59-106	4/9/2019	None detected	
Library South	Next to 3rd floor Women's Rest Room LIB SOU 3001	Drinking Fountain (left)	1910033-LIB510-107	4/9/2019	None detected	
Library South	Next to 3rd floor Women's Rest Room LIB SOU 3001	Drinking Fountain (right)	1910033-LIB511-108	4/9/2019	None detected	
Library South	Next to 3rd floor Men's Rest Room LIB SOU 3057	Drinking Fountain (left)	1910033-LIB512-109	4/9/2019	None detected	
Library South	Next to 3rd floor Men's Rest Room LIB SOU 3057	Drinking Fountain (right)	1910033-LIB513-110	4/9/2019	None detected	
Library South	Next to 4th floor Women's Rest Room LIB SOU 4001	Drinking Fountain (left)	1910033-LIB514-111	4/9/2019	None detected	
Library South	Next to 4th floor Women's Rest Room LIB SOU 4001	Drinking Fountain (right)	1910033-LIB515-112	4/9/2019	None detected	
Library South	Next to 4th floor Men's Rest Room LIB SOU 4057	Drinking Fountain (left)	1910033-LIB516-113	4/9/2019	None detected	
Library South	Next to 4th floor Men's Rest Room LIB SOU 4057	Drinking Fountain (right)	1910033-LIB517-114	4/9/2019	None detected	
Library South	Next to 5th floor Women's Rest Room LIB SOU 5001	Drinking Fountain (left)	1910033-LIB518-115	4/9/2019	None detected	
Library South	Next to 5th floor Women's Rest Room LIB SOU 5001	Drinking Fountain (right)	1910033-LIB519-116	4/9/2019	None detected	
Library South	5th Floor, Room 5007	Prep kitchen	1910033-LIB520-117	4/9/2019	None detected	
Library South	5th Floor, Room 5034B	Break room with sink	1910033-LIB521-118	4/9/2019	None detected	
Library South	Next to 5th floor Men's Rest Room LIB SOU 5057	Drinking Fountain (left)	1910033-LIB522-119	4/9/2019	None detected	
Library South	Next to 5th floor Men's Rest Room LIB SOU 5057	Drinking Fountain (right)	1910033-LIB523-120	4/9/2019	None detected	
Library South	5th Floor, Room 5039C	Office sink	1910033-LIB524-121	4/9/2019	8.65	
Loker Student Union	Taco Bell	Sink	1910033-2L-37	5/14/2018	1.06	
Loker Student Union	Subway	Sink	1910033-2L-44	5/7/2018	1.09	
Loker Student Union	Campus Dining	Sink	1910033-3L-3	5/7/2018	1.09	
Loker Student Union	Campus Dining	Sink	1910033-3L-5	5/7/2018	1.24	
Loker Student Union	Kitchen	Sink	1910033-2L-15	5/14/2018	1.25	
Loker Student Union	Bar	Sink	1910033-2L-12	5/7/2018	1.26	
Loker Student Union	Kitchen	Sink	1910033-2L-24	5/7/2018	1.26	
Loker Student Union	Kitchen	Sink	1910033-2L-19	5/7/2018	1.28	
Loker Student Union	Kitchen	Sink	1910033-2L-17	5/14/2018	1.38	
Loker Student Union	Kitchen	Water Spigot	1910033-2L-21, 1910033-LSV-141 1910033-LSV-142, 1910033-LSU-246, 1910033-LSU-247	5/7/2018, 5/23/2018, 6/11/2018	18.3, 7.82, None detected, 4.82, 1.50	
Loker Student Union	Kitchen	Sink	1910033-2L-26	5/7/2018	1.54	
Loker Student Union	Jamba Juice	Sink	1910033-2L-6, 1910033-LSV-139, 1910033-LSV-140	5/7/2018 and 5/23/2018	37.4, 26.7, 1.56, 22.70	Facility to be replaced
Loker Student Union	Johnnie's Pizzeria	Sink	1910033-2L-34	5/7/2018	1.74	
Loker Student Union	Campus Dining	Sink	1910033-3L-4	5/7/2018	1.90	
Loker Student Union	Union Grind	Sink	1910033-2L-10	5/7/2018	1.97	
Loker Student Union	1910	Water Spigot	1910033-2L-28	5/7/2018	2.35	
Loker Student Union	Bar	Sink	1910033-2L-11	5/7/2018	2.47	
Loker Student Union	Jamba Juice	Sink	1910033-2L-4	5/7/2018	2.50	
Loker Student Union	Union Grind	Sink	1910033-2L-8	5/7/2018	2.71	
Loker Student Union	Subway	Sink	1910033-2L-43	5/7/2018	2.97	
Loker Student Union	Kitchen	Sink	1910033-2L-23	5/7/2018	3.70	
Loker Student Union	Kitchen	Sink	1910033-2L-30	5/14/2018	3.92	
Loker Student Union	Panda Express	Sink	1910033-2L-41	5/7/2018	4.08	
Loker Student Union	Johnnie's Pizzeria	Sink	1910033-2L-32	5/7/2018	4.36	
Loker Student Union	Jamba Juice	Sink	1910033-2L-5	5/7/2018	4.77	
Loker Student Union	Campus Dining	Sink	1910033-3L-7	5/7/2018	5.35	
Loker Student Union	Campus Dining	Sink	1910033-3L-6	5/7/2018	5.49	
Loker Student Union	Jamba Juice	Sink	1910033-2L-3	5/7/2018	9.73	
Loker Student Union	LSU Break Room	Kitchen with sink	1910033-LL-1	5/7/2018	None detected	
Loker Student Union	Between M and W Restrooms	Drinking Fountain	1910033-LL-2	5/7/2018	None detected	
Loker Student Union	Hydration Station	Bottle Filler	1910033-2L-1	5/7/2018	None detected	
Loker Student Union	Hydration Station	Drinking Fountain	1910033-2L-2	5/7/2018	None detected	
Loker Student Union	Union Grind	Sink	1910033-2L-7	5/7/2018	None detected	
Loker Student Union	Union Grind	Sink	1910033-2L-9	5/7/2018	None detected	
Loker Student Union	Bar	Sink	1910033-2L-13	5/7/2018	None detected	
Loker Student Union	Kitchen	Sink	1910033-2L-14	5/7/2018	None detected	
Loker Student Union	Kitchen	Sink	1910033-2L-16	5/14/2018	None detected	
Loker Student Union	Kitchen	Sink	1910033-2L-18	5/7/2018	None detected	
Loker Student Union	Kitchen	Sink	1910033-2L-20	5/7/2018	None detected	
Loker Student Union	Kitchen	Sink	1910033-2L-22	5/7/2018	None detected	
Loker Student Union	Kitchen	Sink	1910033-2L-25	5/7/2018	None detected	
Loker Student Union	Kitchen	Sink	1910033-2L-27	5/7/2018	None detected	
Loker Student Union	Kitchen	Sink	1910033-2L-29	5/7/2018	None detected	
Loker Student Union	Johnnie's Pizzeria	Sink	1910033-2L-33	5/7/2018	None detected	
Loker Student Union	Taco Bell	Sink	1910033-2L-35	5/14/2018	None detected	
Loker Student Union	Taco Bell	Sink	1910033-2L-36	5/7/2018	None detected	
Loker Student Union	Taco Bell	Sink	1910033-2L-47	5/7/2018	None detected	
Loker Student Union	Panda Express	Sink	1910033-2L-38	5/7/2018	None detected	
Loker Student Union	Panda Express	Sink	1910033-2L-39	5/7/2018	None detected	
Loker Student Union	Panda Express	Sink	1910033-2L-40	5/7/2018	None detected	
Loker Student Union	Subway	Sink	1910033-2L-42	5/7/2018	None detected	
Loker Student Union	Subway	Sink	1910033-2L-46	5/14/2018	None detected	
Loker Student Union	Near East Restroom	Drinking Fountain	1910033-3L-1	5/7/2018	None detected	
Loker Student Union	Near West Restroom	Drinking Fountain	1910033-3L-2	5/7/2018	None detected	

CSUDH Potable Water Lead Testing
Sampling and lab result summary

Building Name	Location	Source Type	Sample ID(s)	Date Sampled	Result	Comments
Natural Sciences & Math	Near NSM A-124	Drinking Fountain	1910033-NSM1-43	12/4/2018	1.29	
Natural Sciences & Math	Near E-228	Drinking Fountain	1910033-NSM1-44	12/4/2018	1.84	
Natural Sciences & Math	Near NSM E-128	Drinking Fountain	1910033-NSM1-42	12/4/2018	2.70	
Natural Sciences & Math	Near E-328	Drinking Fountain	1910033-NSM1-45	12/4/2018	2.87	
Social & Behavioral Sciences	Next to SBS A-301	Drinking Fountain	1910033-SBS5-57	12/7/2018	2.41	
Social & Behavioral Sciences	Next to SBS A-339	Drinking Fountain	1910033-SBS6-58	12/7/2018	3.00	
Social & Behavioral Sciences	Next to SBS B-307	Drinking Fountain	1910033-SBS4-56	12/7/2018	9.17	
Social & Behavioral Sciences	Older adult Center SBS B-235	Kitchen with sink	1910033-SBS10-62,	12/7/2018,	17.4, 25.4, None	Facility to be replaced
Social & Behavioral Sciences	Next to SBS C-309	Drinking Fountain	1910033-SBS1-53	12/7/2018	None detected	
Social & Behavioral Sciences	Next to SBS C-335	Drinking Fountain	1910033-SBS2-54	12/7/2018	None detected	
Social & Behavioral Sciences	Across from SBS B-215	Drinking Fountain	1910033-SBS7-59	12/7/2018	None detected	
Social & Behavioral Sciences	Across from SBS B-215	Drinking Fountain	1910033-SBS8-60	12/7/2018	None detected	
Social & Behavioral Sciences	Next to SBS B-232	Bottle Filler	1910033-SBS9-61	12/7/2018	None detected	
Social & Behavioral Sciences	Next to SBS A-110C	Drinking Fountain	1910033-SBS11-63	12/7/2018	None detected	
Social & Behavioral Sciences	Next to SBS A-110C	Drinking Fountain	1910033-SBS12-64	12/7/2018	None detected	
Small College Complex - 1	East side of building next to Room 108	Drinking Fountain	1910033-SCC1-48	12/7/2018	None detected	
Small College Complex - 2	SCC 200 Parking Control Office, Break Room	Sink	1910033-SCC2-49	12/7/2018	3.08	
Student Health Center	Near SHC B-119 Women's Rest Room	Drinking Fountain	1910033-SHC2-66	12/7/2018	1.07	
Student Health Center	Near A-129	Drinking Fountain	1910033-SHC6-74	12/7/2018	3.76	
Student Health Center	SHC A-145, Break Room	Sink	1910033-SHC1-65	12/7/2018	3.84	
Student Health Center	Near SHC C-111 X-Ray Suite	Drinking Fountain	1910033-SHC3-67	12/7/2018	4.50	
Student Health Center	Next to SHC A-120 Observation Room	Drinking Fountain	1910033-SHC4-68	12/7/2018	5.70	
Student Health Center	SHC A-109, storage room	Sink	1910033-SHC5-69,	12/7/2018,	21.0, 23.9, 27.8, 27.9	Facility to be replaced
Softball Field	Left dugout	Drinking Fountain	1910033-SF1-127	5/9/2019	1.50	
Softball Field	Right dugout	Drinking Fountain	1910033-SF2-128	5/9/2019	1.84	
South Academic Complex 2	SAC 2132	Break room with sink	1910033-SAC1-122	5/9/2019	1.27	
South Academic Complex 2	Next to Men's Rest Room SAC 2109	Drinking Fountain	-	-	Not Sampled	No access due to construction
South Academic Complex 3	Next to Men's Rest Room SAC 3170	Drinking Fountain	1910033-SAC2-123	5/9/2019	None detected	Broken, but sampled
South Academic Complex 3	Near SAC 3134	Drinking Fountain	1910033-SAC3-124	5/9/2019	None detected	
South Academic Complex 3	SAC 3127	Kitchen with sink	1910033-SAC4-125	5/9/2019	None detected	
University Theatre	2nd Floor lobby near Men's Rest Room	Drinking Fountain	1910033-UT3-72	12/7/2018	4.65	
University Theatre	2nd Floor lobby near Men's Rest Room	Drinking Fountain	1910033-UT2-71	12/7/2018	5.47	
University Theatre	Across from SHC A-106	Drinking Fountain	1910033-UT1-70	12/7/2018	8.65	
Welch Hall	WH-450G	Kitchen with sink	1910033-WH1-81	4/4/2019	3.84	
Welch Hall	WH-B470K	Sink in conference room	1910033-WH2-82	4/4/2019	1.62	
Welch Hall	WH-440F	Break room with sink	1910033-WH3-83	4/4/2019	None detected	
Welch Hall	WH-A433	Kitchen with sink	1910033-WH4-84	4/4/2019	None detected	
Welch Hall	WH-C303	Sink in conference room	1910033-WH5-85	4/4/2019	None detected	
Welch Hall	WH-C290	Office sink	1910033-WH6-86	4/4/2019	None detected	
Welch Hall	WH-B100Q	Break room with sink	1910033-WH7-87	4/4/2019	None detected	
Welch Hall	WH-A130B	Office sink	1910033-WH8-88	4/4/2019	None detected	
Welch Hall	Next to 1st floor Women's Rest Room WH 166	Bottle Filler	1910033-WH9-89	4/4/2019	None detected	
Welch Hall	Next to 1st floor Women's Rest Room WH 166	Drinking Fountain (middle)	1910033-WH10-90	4/4/2019	None detected	Broken, but sampled
Welch Hall	Next to 1st floor Women's Rest Room WH 166	Drinking Fountain (left)	1910033-WH11-91	4/4/2019	None detected	
Welch Hall	Next to 2nd floor Women's Rest Room WH 234	Drinking Fountain (left)	1910033-WH12-92	4/4/2019	None detected	
Welch Hall	Next to 2nd floor Women's Rest Room WH 234	Drinking Fountain (right)	1910033-WH12-93	4/4/2019	None detected	
Welch Hall	Next to 3rd floor Women's Rest Room WH 338	Drinking Fountain (left)	1910033-WH13-94	4/4/2019	None detected	
Welch Hall	Next to 3rd floor Women's Rest Room WH 338	Drinking Fountain (right)	1910033-WH13-95	4/4/2019	None detected	
Welch Hall	Next to 4th floor Women's Rest Room WH 438	Drinking Fountain (left)	1910033-WH14-96	4/4/2019	None detected	
Welch Hall	Next to 4th floor Women's Rest Room WH 438	Drinking Fountain (right)	1910033-WH14-97	4/4/2019	None detected	